



Harris County Fire Marshal's Office

2318 Atascocita Road
Humble, Texas 77396

Tel: 281-436-8030 Fax: 281-436-8005 www.hcfmo.net

Retail Fireworks Stand Notice of Inspection

Date: \_\_\_\_\_

Inspector Unit # \_\_\_\_\_

Inspector Name \_\_\_\_\_

Address: \_\_\_\_\_

State permit # \_\_\_\_\_

City: \_\_\_\_\_

H. C. Permit # \_\_\_\_\_

Permittee: \_\_\_\_\_

Permittee Tel # \_\_\_\_\_

Deficiencies (check if Deficient)

- 34.817(j) 1 No valid state retail permit
34.809(c) 2 Original permit not posted or available at time of inspection
34.809(d) 3 Permit defaced or altered
5609.1.3 4 No Fire Code Certificate of Compliance or Permit
34.817(f) 5 Selling fireworks from tent or motor vehicle
34.817(k) 6 Selling fireworks from a single or multifamily residential structure
5609.4.1 7 Physical address numbers not posted or (4" high, 1/2" width)
5609.4.1 8 24-hour emergency contact number not posted on outside of stand
34.817(g) 9 Smoking inside or smoking within 10 ft of stand
34.817(g) 10 Fireworks and "No Smoking" signs not posted on outside or inside
34.817(a) 11 Site is unsupervised (no operator on duty)
34.817(a) 12 Supervisor less than 18 years old
2154.003 13 Illegal fireworks e.g. bottle rockets
34.817(o) 14 Fireworks do not conform to USCPSC or manufacturer labels
2154.252(c) 15 Fireworks sold or offered to children under 16 years of age
2154.252(c) 16 Fireworks sold to intoxicated or incompetent person
34.817(h) 17 Consumption or possession of an alcoholic beverage
34.817(h) 18 Supervisor or sales personnel consuming or under influence of alcohol
34.817(i) 19 Display / sale within building or structure where other items are sold
2154.251(a8) 20 Illegal sale, storage, manufacture, distribution, or display
2154.202(g) 21 Offering for sale outside of sales season
34.817(l) 22 No off highway parking provided
34.817(c) 23 Heat sealing in retail site
5609.4.3 24 >125 lbs of pyrotechnic material or 25% gross wt of fwks in building
5609.4.4 (3) 25 Sales or storage within 5 ft of another stand
T5609.4.1 26 Sales or storage within 10 ft of vehicle parking
T5609.4.1 27 Sales or storage within 20 ft of other buildings
T5609.4.1 28 Sales or storage within 30 ft of combustibles
T5609.4.1 29 Sales or storage within 50 ft of cooking or open flame equipment
T5609.4.1 30 Sales or storage within 100 ft of flammable or combustible dispensing
5609.4.5.4.1 31 Generator <10 ft from stand, grass, trash, combustible, flammable
5609.4.5.4.2 32 Generator fuel not in safety can or stored <10 ft from stand
5609.4.6.1 33 Stand <16 ft doesn't have 1 walk door which opens outward
5609.4.6.2 34 Egress travel exceeds 35 ft
5609.4.6 35 Aisle, doors, exit discharge not clear of all items
5609.4.6.3 36 Walk doors <28" wide by 72" high or door locked from outside
34.818(4) 37 Fireworks sales or display within reach of customer
5609.4.6.4 38 Counter <6 ft from back of stand or exit aisle width <28"
5609.2.4.5(5.1) 39 No 2A fire extinguisher within 75 ft of storage for fireworks
34.818(d) 40 No 1A fire extinguisher located within stand
34.818(9) 41 No 6-B,C fire ext. within 75' of generator
34.818 42 Posters, signs, decorations on interior surface
5609.4.7.2 43 Cooking in or < 50' from stand
5609.4.5.3 44 Light fixtures within 25 ft of fireworks do not have guards
5609.4.7.4 45 Improper flame break
34.818(5) 46 Electrical service <8 ft overhead or not buried underground
34.818(6) 47 No electrical master switch by exit (inside or outside) of stand
34.818(7) 48 Electrical wiring or equipment does not meet electrical code
34.818(7) 49 Electrical splices or connections not in enclosed junction box (interior)
34.818(8) 50 Drop cord, extension cord or bare wiring used within stand
34.818(7) 51 Wiring and/or lights not maintained to prevent accidental contact
5609.4.7.1 52 Smoke detector not installed in sleeping area and/or within stand
34.817(m) 53 High grass, empty boxes, or trash <10 ft from stand
34.818(10) 54 Heater has open flame / heating element or no tip-over cutoff switch
34.818(11) 55 Suitable locking device(s) not provided when unattended

ACTION REQUIRED BY OPERATOR/SUPERVISOR
Correct violations within 24 hours
Close stand until required action is complete
Correct before next selling season
Qualified electrician - Inspect to NEC

Inspection Results

- Y N Certificate of Compliance authorized?
Y N Re-Inspection Required?
Y N Re-Inspection Fee Required?
Noncompliant - Voluntary closure
Citation Issued #
Call \_\_\_\_\_ when violations are corrected

The item(s) noted above are violations of the Harris County Fire Code, Occupations Code Chapter 2154 & the Fireworks Rules 28TAC§34.800 et. seq. and may not include other conditions that were not observed during the inspection. This report should not be viewed as an approval or acknowledgement of compliance with all applicable laws. It is the responsibility of the licensee or permittee to comply with all state and federal laws, rules and requirements while engaging in the sales and storage of fireworks. 28TAC §34.817(a) states "It is the responsibility of the permit holder as well as the supervisor to comply with or require compliance with the fireworks rules".

I ASSUME RESPONSIBILITY that I will correct or have corrected the above deficiencies to comply with the Harris County Fire Code, Texas Occupations Code Chapter 2154 & The Fireworks Rules.

Site Supervisor Signature: \_\_\_\_\_

Site Supervisor Printed Name: \_\_\_\_\_